

GENERAL NOTES

1. THE UTILITY DESIGN DETAILS SUMMARIZED ON THIS SHEET ARE FOR PROPERTY OWNER REVIEW. THE CONTRACTOR SHALL REFERENCE THE UTILITY DESIGN PACKAGE (UDP), PROVIDED WITH THE ISSUED FOR CONSTRUCTION DRAWINGS FOR BIDDING. THE CONTRACTOR SHALL INSTALL THE UTILITY RELATED SCOPE OF WORK PER UTILITY CONSTRUCTION SPECIFICATION REQUIREMENTS.
2. UTILITY EQUIPMENT INSTALLATIONS AND PREP WORK AND TERMINATION OF SERVICE CONDUCTORS SHALL BE COORDINATED WITH THE APPROPRIATE UTILITY ENGINEER AT TIME OF PRE-CONSTRUCTION MEETING TO ENSURE ACCURACY OF INSTALLATIONS.
3. FOR GENERAL NOTES AND SYMBOL LIST, SEE E-7.
4. BEFORE BID SUBMISSION AND COMMENCING WORK, CONTRACTOR SHALL FIELD INSPECT SCOPE OF PROJECT, AND SUBMIT A REQUEST OF INFORMATION TO THE ENGINEER FOR ANY DISCREPANCIES OR INCOMPATIBILITIES FOUND BETWEEN DESIGN AND ACTUAL CONDITIONS.
5. ALL JUNCTION OR OUTLET BOXES SHALL BE INSTALLED SO AS TO ALLOW ACCESS TO COVER. PROVIDE APPROVED ACCESS DOORS OR PLATES AS REQUIRED IN AREAS WHERE UNOBSTRUCTED ACCESS TO BOX OR OUTLET IS NOT POSSIBLE.
6. EQUIPMENT LOCATIONS, WHERE SHOWN, ARE APPROXIMATE. FIELD VERIFY AND COORDINATE WITH OWNER, INCLUDING OTHER CONSTRUCTION RELATED INFORMATION.
7. ALL WORK TO BE PERFORMED AS PER LATEST LOCAL AHJ APPROVED EDITION OF NEC, AND LATEST LOCAL UTILITY SPECIFICATIONS.

KEYNOTES

1. PROVIDE (3) 4" PVC CONDUIT FROM UTILITY TRANSFORMER SECONDARY (WITH BUILT-IN C/T UTILITY COMPARTMENT) TO SWITCHBOARD & ADJACENT METER CAN. THE CONTRACTOR TO COORDINATE WITH UTILITY FOR FINAL LOCATIONS, QUANTITY CONDUITS AND ADDITIONAL REQUIREMENTS.
2. PROPOSED SERVICE ELECTRICAL INFRASTRUCTURE. REFER TO POWER RISER FOR ADDITIONAL INFORMATION.
3. PROVIDE CONDUIT(S) FROM SWITCHBOARD TO 350KW POWER UNIT TO 350KW DISPENSER AS REQUIRED. REFER TO DRAWING E-3 FOR ADDITIONAL INFORMATION.




EVgo SERVICES, LLC
11835 W OLYMPIC BLVD STE 900 E
LOS ANGELES, CA 90064



Job Name:
**WAWA #0157
NORTH WALES**

593 DEKALB PIKE -EV
NORTH WALES, PA 19454

SHEET DESCRIPTION:
**ELECTRICAL
UTILITY PLAN**



Project #: P17773
File:
Drawn by: KC
Date(s): 07/25/2022
2022.07.25 - DD100 PRELIMINARY DESIGN
2022.08.08 - ISSUED FOR PERMIT

UTILITY PLAN
SCALE: 1/16" = 1'-0"

